

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-0694:238 Page 1 of 1

CATEGORY: Duct Detector Housing/Base

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02050
Contact: Anthony J. Shalna (781) 471-3000 *FAX (781) 471-3099

DESIGN: Models ADS-P200, *ADP, and *ADP-R duct smoke detectors. Units consist of a housing, relay, electrical components, sampling and exhaust tubes and an integral photoelectric smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, air velocity rating, and UL label.

APPROVAL: Listed as duct detector units when used with listee's separately listed compatible fire alarm control units. Intended for use in HVAC systems having air velocities between 500 to 4000 ft/min. *Models ADP and ADP-R intended for use in HVAC systems having air velocities between 100-4000ft/min. Also suitable for use as a stand-alone unit where permitted. Refer to listee's Installation Instruction Manual for details.

XLF: 3240-1209:155

*Rev. 07-31-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 31, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**